

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:113 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Models SIGA-CC1, SIGA-CC2, SIGA-CT1, SIGA-CT2, SIGA-CR, SIGA-UM, SIGA-MM1, SIGA-WTM, SIGA-IM, SIGA-MDM, SIGA-MAB, SIGA-MCT2, SIGA-MCC1, SIGA-MCC2, SIGA-MCR, SIGA-MCRR remote transponders; Models SIGA-AA30, SIGA-AA50 audio amplifier; Model SIGA-APS, SIGA-APS-220 power supply and mounting plate Model SIGA-MB4. Models *SIGA-CC1S and *SIGA-MCC1S Auto-Sync Output Modules. Refer to listee's data sheet for additional detailed product description and operational consideration.

RATING: 15.2 - 19.95 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units.

XLF: 7300-1591:121

*Rev. 11-22-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 1, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager